

STATEMENT OF CONFORMITY

Ref.no.: 2089661.02A

Product

Appliance inlet for industrial use

Tested by request of

Ratio Electric
Ambachtsstraat 12
3861 RH Nijkerk
The Netherlands

Manufactured at (name and place)

Ratio Electric
Nijkerk, The Netherlands

Rating and principal characteristics

16 A, 250 V~, IP56

Trademark (if any)

Ratio

Model/Type Ref

MP16 -10

Additional information (if any)

-

A sample of the product has been tested and found to be in conformity with the current HD/EN and equivalent national standard, (number and edition)

IEC 60 309-1:1999 + A1:2005

IEC 60 309-2:1999 + A1:2005

As shown in the Test Report (ref. No.)

2089661.02A


This Statement of Conformity is result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standard.

KEMA Quality B.V.

Arnhem,

Date: June 15, 2006

Signature:



H.R.M. Barends